CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

NABL - Accredited Laboratory as per ISO / IEC-17025 :2005

T-2377

Job No.: CTCE/BBMP/KRIDL/W.No.12/CSR-11/988e/CEMENT/2015-16 Date: 09.11.2015

TEST REPORT ON CEMENT

* CUSTOMER	:	**Asst. Executive Engineer**, Project Sub Division, BBMP, Bangalore.
*AGENCY	:	**Technical Manager,** KRIDL, Bangalore.
*NAME OF THE WORK	:	Providing Chain Link Fencing to Shettyhalli Burial Ground in Ward No.12 in Project Sub Division, BBMP, Bangalore.
*REFERENCE	:	BBMP/AEE/PSD/DZ/PR/2014-15 Dated: 07.11.2015
SAMPLE ID	:	Cement
SAMPLE RECEIVED ON	:	07.11.2015
PERIOD OF TESTING	:	07.11.2015 to 09.11.2015

The results of the tests conducted on the cement sample are as follows:

Sl. No	Descriptions	Test Method as per IS	Test Result	Requirements as per IS: 8112-2013
1	Standard Consistency	IS-4031 (Part -4) 1988(RA-2009)	29.00 %	-
2	a) Initial Setting Time	IS-4031 (Part -5) 1988(RA-2009)	140 Minutes	Not Less than 30 Minutes
	b) Final Setting Time	IS-4031 (Part -5) 1988(RA-2009)	475 Minutes	Not More than 600 Minutes
3	Soundness by Le Chartlier Method	IS-4031 (Part-3) 1988(RA-2009)	1 mm	Not more than 10mm

*Information is furnished by the Customer/Representative.

Note:

⇒ The report shall not be reproduced, except in full, without the written approval of the laboratory.

⇒ The results indicated above are based on the tests carried out on the samples received in the laboratory.

⇒ Any Query regarding the report must be reported within 30 days from the date of testing.

****

VISHWANATH .C
Quality Manager

#23/14, 7th Cross, 3rd Stage, 4th Block, Shakthi Ganapathi Nagara, Basaveshwaranagar, Bangalore-79.
Tele Fax : 23223227, Website : www.civiltechconsultants.com
E-mail : vishwanath.ia@civiltechconsultants.com / info@civiltechconsultants.com

CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

NABL - Accredited Laboratory as per ISO / IEC-17025 :2005

T-2377

Job No.: CTCE/BBMP/KRIDL/W.No.12/CSR-11/988e/SAND-Gradation/2015-16 : 09.11.2015

TEST REPORT ON DETERMINATION GRADATION OF FINE AGGREGATES

*** Customer** : **Asst. Executive Engineer,** Project Sub Division, BBMP, Bangalore.

*** Agency** : **Technical Manager,** KRIDL, Bangalore.

*** Name of Work** : Providing Chain Link Fencing to Shettyhalli Burial Ground in Ward No.12 in Project Sub Division, BBMP, Bangalore.

Reference : BBMP/AEE/PSD/DZ/PR/2014-15 Dated: 07.11.2015

Technical Reference : IS : 2386 Part 1 - 1963 RA-2007

Sample ID : Fine Aggregates

Sample Received on : 07.11.2015

Date of Testing : 09.11.2015

Total Wt. of Aggregates in gms **1000**

Is Sieve Size in mm	Cumulative Weight Passing in %	Specific Limits as per IS 383-1970 (RA- 2007)			
		Zone-I	Zone-II	Zone-III	Zone-IV
10	100	100	100	100	100
4.75	95.50	90-100	90-100	90-100	95-100
2.36	83.30	60-95	75-100	85-100	95-100
1.18	60.80	30-70	55-90	75-100	90-100
600 Micron	32.30	15-34	35-59	60-79	80-100
300 Micron	13.80	5-20	8-30	12-40	15-50
150 Micron	4.60	0-10	0-10	0-10	0-15

* Information is furnished by the Customer/Representative

Remarks : This sample is under Zone-I specific limits.

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

****

VISHWANATH .C
Quality Manager

#23/14, 7th Cross, 3rd Stage, 4th Block, Shakthi Ganapathi Nagara, Basaveshwaranagar, Bangalore-79.
Tele Fax : 23223227, Website : www.civiltechconsultants.com
E-mail : vishwanath.ia@civiltechconsultants.com / info@civiltechconsultants.com

CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

NABL - Accredited Laboratory as per ISO / IEC-17025 :2005

T-2377

Job No.: CTCE/BBMP/KRIDL/W.No.12/CSR-11/988e/AGG/GR/2015-16 : 09.11.2015

TEST REPORT ON COARSE AGGREGATES

*** Customer** : **Asst. Executive Engineer,** Project Sub Division, BBMP, Bangalore.

*** Agency** : **Technical Manager,** KRIDL, Bangalore.

*** Name of Work** : Providing Chain Link Fencing to Shettyhalli Burial Ground in Ward No.12 in Project Sub Division, BBMP, Bangalore.

Reference : BBMP/AEE/PSD/DZ/PR/2014-15 Dated: 07.11.2015

Technical Reference : IS : 2386 Part 1 -1963 RA-2007

Sample ID : Coarse Aggregates (40mm)

Sample Received on : 07.11.2015

Date of Testing : 09.11.2015

Total Wt. of Aggregates in gms= **10000**

Is Sieve Size in mm	Cumulative Weight Passing in %	Specific Limits as per IS 383-1970 (RA- 2007)	
		Graded	Single Sized
80	100	100	-
63	100	-	100
40	96.95	95-100	85-100
20	48.45	30-70	0-20
10	22.80	10-35	0-5
4.75	2.30	0-5	-

* Information is furnished by the Customer/Representative

Remarks : This sample is under Graded specific limits.

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

****

VISHWANATH .C
Quality Manager

#23/14, 7th Cross, 3rd Stage, 4th Block, Shakthi Ganapathi Nagara, Basaveshwaranagar, Bangalore-79.
Tele Fax : 23223227, Website : www.civiltechconsultants.com
E-mail : vishwanath.ia@civiltechconsultants.com / info@civiltechconsultants.com

CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

An ISO 9001:2008 Certified Company

NABL - Accredited Laboratory as per ISO / IEC-17025 : 2005

JAS-ANZ BSCIC ISO 9001 REGISTERED

Job No.: CTCE/BBMP/KRIDL/W.No.12/MS Angle/2015-16

16.11.2015

TEST REPORT ON STRUCTURAL STEEL

Customer : **Asst. Executive Engineer,** Project Sub Division, BBMP, Bangalore.

Agency : **Technical Manager,** KRIDL, Bangalore.

Name of work : Providing Chain Link Fencing to Shettyhalli Burial Ground in Ward No.12 in Project Sub Division, BBMP, Bangalore.

Reference : BBMP/AEE/PSD/DZ/PR/2014-15 Dated: 07.11.2015

Samples ID : Samples Supplied By Agency

Specimen Size : ISA-65X65X6mm (1m Length)

Sl.No	Description	Result
1	Thickness	6.04 mm
2	Width	65.02 mm
3	Weight / Meter	5.88 Kg

Civil-Tech Consultants & Engineers Bangalore

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory
3. Any Query regarding the report must be reported within 30 days from the date of testing.

****

M/s. Civil-Tech Consultants & Engineers
23/14, 7th Cross, 3rd Stage,
4th Block, Shakthiganapathinagara,
Basaveshwaranagar,
Bangalore-560079.

CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

An ISO 9001:2008 Certified Company

NABL - Accredited Laboratory as per ISO / IEC-17025 : 2005

JAS-ANZ BSCIC ISO 9001 REGISTERED

Job No.: CTCE/BBMP/KRIDL/W.No.12/MS Pipe/2015-16 16.11.2015

TEST REPORT ON M.S PIPE (38mm Dia)

Customer : **Asst. Executive Engineer,** Project Sub Division, BBMP, Bangalore.

Agency : **Technical Manager,** KRIDL, Bangalore.

Name of work : Providing Chain Link Fencing to Shettyhalli Burial Ground in Ward No.12 in Project Sub Division, BBMP, Bangalore.

Reference : BBMP/AEE/PSD/DZ/PR/2014-15 Dated: 07.11.2015

Specimen Size : M.S Pipe 38mm Dia

PHYSICAL TEST

Sl.No	Description	Result
1	Thickness	1.98 mm
2	Inner Diameter	38.10 mm
3	Outer Diameter	42.06 mm
4	Weight / Meter	1.86 kg

Civil-Tech Consultants & Engineers Bangalore

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

****

M/s. Civil-Tech Consultants & Engineers

23/14, 7th Cross, 3rd Stage,
4th Block, Shakthiganapathinagara,
Basaveshwaranagar,
Bangalore-560079.

CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

An ISO 9001:2008 Certified Company

NABL - Accredited Laboratory as per ISO / IEC-17025 : 2005

JAS-ANZ BSCIC ISO 9001 REGISTERED

Job No.: CTCE/BBMP/KRIDL/W.No.12/Fencing/2015-16 16.11.2015

TEST REPORT ON CHAIN LINK FENCING WIRE (8th Gauge)

Customer : **Asst. Executive Engineer,** Project Sub Division, BBMP, Bangalore.

Agency : **Technical Manager,** KRIDL, Bangalore.

Name of work : Providing Chain Link Fencing to Shettyhalli Burial Ground in Ward No.12 in Project Sub Division, BBMP, Bangalore.

Reference : BBMP/AEE/PSD/DZ/PR/2014-15 Dated: 07.11.2015

Samples ID : Samples Supplied By Agency

Sl.No	Description	Result
1	Diameter	4.02 mm
2	Internal Spacing	50 mm X 50 mm
3	Weight / Meter (1m x 1m)	4.18 Kg

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory
3. Any Query regarding the report must be reported within 30 days from the date of testing.

******

M/s. Civil-Tech Consultants & Engineers
23/14, 7th Cross, 3rd Stage,
4th Block, Shakthiganapathinagara,
Basaveshwaranagar,
Bangalore-560079.

#23/14, 7th Cross, 3rd Stage, 4th Block, Shakthi Ganapathi Nagara, Basaveshwaranagar, Bangalore-79.
Tele Fax : 23223227, Website : www.civiltechconsultants.com
E-mail : vishwanath.ia@civiltechconsultants.com / info@civiltechconsultants.com

CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

NABL - Accredited Laboratory as per ISO / IEC-17025 :2005

T-2377

Job No.: CTCE/BBMP/KRIDL/W.No.12/CSR-11/988e/CUBE/2015-16 25.12.2015

TEST REPORT ON COMPRESSIVE STRENGTH OF CONCRETE CUBES

***Customer** : **Asst. Executive Engineer,** Project Sub Division, BBMP, Bangalore.

***Agency** : **Technical Manager,** KRIDL, Bangalore.

***Name of the work** : Providing Chain Link Fencing to Shettyhalli Burial Ground in Ward No.12 in Project Sub Division, BBMP, Bangalore.

Reference : BBMP/AEE/PSD/DZ/PR/2014-15 Dated: 07.11.2015

***Sample ID** : Cement Concrete

Size of cubes : 150mmx150mmx150mm

Cross Sectional Area : 22500 mm^2

Technical Reference : IS: 516-1959 (Reaffirmed 2008)

***Grade of Concrete** : M_{20}

Compressive Strength as on : 28th day

Sample Received on : 25.12.2015

Sl.No.	*Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	27.11.2015	25.12.2015	8.163	493.2	21.92
2	27.11.2015	25.12.2015	8.354	518.6	23.05
3	27.11.2015	25.12.2015	8.275	502.4	22.33

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

****

VISHWANATH .C
Quality Manager

#23/14, 7th Cross, 3rd Stage, 4th Block, Shakthi Ganapathi Nagara, Basaveshwaranagar, Bangalore-79.
Tele Fax : 23223227, Website : www.civiltechconsultants.com
E-mail : vishwanath.ia@civiltechconsultants.com / info@civiltechconsultants.com